



Loudoun County Health Department

P.O. Box 7000
Leesburg VA 20177-7000



Environmental Health
Phone: 703 / 777-0234
Fax: 703 / 771-5023

Community Health
Phone: 703 / 777-0236
Fax: 703 / 771-5393

February 5, 2008

MEMORANDUM TO: Stephen Gardner, Project Manager MSC 60A
Department of Planning

FROM: Joseph E. Lock MSC 68
Rural Section Supervisor
Division Of Environmental Health

SUBJECT: SPEX 2007-0053, Washington Immanuel Presbyterian Church
LCTM 91-8A, PIN 243498730



The above referenced project meets the requirements of Section 1245.10 of the LSDO for:

	Yes	No	N/A
a. Proposed Drainfield Sites	_____	_____	<u>X</u>
b. Proposed Wells	_____	<u>X</u>	_____

The locations on the plat, submitted by Tri-Tek Engineering revised January 14, 2008, are correct as shown:

a. Wells (existing and proposed)	_____	<u>X</u>	_____
b. Drainfields (Existing)	<u>X*</u>	_____	_____

Health Department staff recommends: Approval _____ Denial X
Approval with conditions _____

Items that are incorrect/deficient are listed on the attached page.

Attachments Yes X No _____

If further information or clarification on the above project is required, please contact me at (703)771-5800.

JEL/JDF/jel

C:WashingtonImmanuel.Referral

(Signature)



**SPEX 2007-0053
LCTM 91-8A
February 5, 2008
Page 2**

ATTACHMENT

*A pump and haul permit (247 SR/P&H 98) was issued to American Produce in 1998. The pump and haul tank was installed in 1999 for the existing use as a warehouse for 31-45 employees to provide sewage disposal facilities which the property was lacking.

The Board of Supervisors voted on December 3, 2001 not to approve the Permanent Pump and Haul for Fairfax Church of God/American Produce.

The existing pump and haul is not approved as a permanent pump and haul for the current structure. The facility and pump and haul must be approved for permanent use under the Sewage Handling and Disposal Regulations. (12 VAC 5-610-599.3)

No records exist for the existing well. A well meeting public standards must be applied for and installed if the Special Exception and Permanent Pump and Haul is approved. The actual standards cannot be determined at this time with the limited information provided.